



中国国家强制性产品认证证书



证书编号: 2020322313000216

认证委托人名称: 上海友邦电气(集团)股份有限公司

认证委托人地址: 上海市松江区佘山镇吉业路528号

生产者名称: 上海友邦电气(集团)股份有限公司

生产者地址: 上海市松江区佘山镇吉业路528号

生产企业名称: 上海友邦电气(集团)股份有限公司

企业地址: 上海市松江区佘山镇吉业路528号

产品名称: 接线端子排

系列、规格、型号: UJ系列, UKJ系列

标准: GB/T 3836.1-2021、GB/T 3836.3-2021

认证模式: 型式试验+初始工厂检查+获证后监督

上述产品符合 CNCA-C23-01:2019 《强制性产品认证实施规则 防爆电气》的要求, 特发此证。
产品相关信息详见附件。

发证日期: 2023年03月22日

有效期至: 2025年06月03日

首次发证日期: 2020年06月04日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书的相关信息可通过国家认监委网站 www.cnca.gov.cn 查询



批准:



上海仪器仪表自控系统检验测试所有限公司

<http://www.sitiias.com.cn>

中国·上海·漕宝路103号200233

电话: +86 21 64510844

S 0008716



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION



CERTIFICATE NO: 2020322313000216

APPLICANT: Shanghai UPUN Electric Group Co.,Ltd.
ADDRESS: No.528,Jiye Rd.,Sheshan Town,
Songjiang District,Shanghai,P.R.China
MANUFACTURER: Shanghai UPUN Electric Group Co.,Ltd.
ADDRESS: No.528,Jiye Rd.,Sheshan Town,
Songjiang District,Shanghai,P.R.China
FACTORY: Shanghai UPUN Electric Group Co.,Ltd.
ADDRESS: No.528,Jiye Rd.,Sheshan Town,
Songjiang District,Shanghai,P.R.China

PRODUCT: Terminal Block
SERIES,SPECIFICATION,MODEL: UJ series, UKJ series
STANDARDS: GB/T 3836.1-2021、GB/T 3836.3-2021

Type of Certification: Type test + Initial inspection + Surveillance inspection

This is to certify that the above mentioned product(s) complies with the requirements of implementation rules for compulsory certification (REFNO. CNCA-C23-01:2019).

Refer to the attachment for detailed information.

Valid from: March 22, 2023

Valid until: June 3, 2025

Date of original certification: June 4, 2020

The validity of this certificate is subject to positive result of the periodic surveillance by issuing certification body until the expiry date.

This certificate is available through CNCA's website: www.cnca.gov.cn



APPROVAL:

Guo AiHua



Shanghai Inspection and Testing Institute of Instruments and Automation Systems Co., Ltd.

<http://www.sitiilas.com.cn>

Building 9, 103 Cao Bao Road, Shanghai 200233, China

Tel: +86 21 64510844

S 0007018



中国国家强制性产品认证证书



证书编号: 2020322313000216

附 件

产品名称: 接线端子排

型号规格: UKJ-1.5、UKJ-1.5MT、UKJ-1.5MT/1×2、UKJ-1.5MT/2-2、UKJ-1.5MT/2×2、UKJ-2.5、UKJ-2.5X、UKJ-2.5M、UKJ-2.5N、UKJ-2.5E、UKJ-2.5NEE、UKJ-2.5EE、UKJ-2.5XE、UKJ-2.5XEE、UKJ-2.5/1×2、UKJ-2.5/2×2、UKJ-2.5/2-2、UKJ-2.5/2-2L、UKJ-2.5M/2-2、UKJ-2.5M/2×2、UKJ-4、UKJ-4C、UKJ-4M、UKJ-10、UKJ-10/2×2、UKJ-10/4×4、UKJ-10EE、UKJ-4E、UKJ-4 EE、UKJ-4/1×2、UKJ-4/2×2、UKJ-4/2×2L、UKJ-4/2-2、UKJ-4/2-2L、UKJ-6、UKJ-6S、UKJ-6SEE、UKJ-6SB、UKJ-6SE、UKJ-6M、UKJ-6EE、UKJ-6/3×6、UKJ-6/5×6、UKJ-W2.5、UKJ-W2.5/2-2、UKJ-W2.5/2×2、UKJ-W4、UKJ-DK1.5、UKJ-DKD1.5、UKJ-DLK4/JD、UKJ-VIOK1.5-3D/JD、UKJ-VIOK1.5-2D、UKJ-DKD1.5-PV、UKJ-DOKD1.5-TG、UKJ-DOK1.5、UKJ-DOK1.5-2D、UKJ-DKD1.5-TG、UKJ-16、UKJ-16EE、UKJ-25/4×6、UKJ-35、UKJ-35N、UKJ-35EE、UKJ-50、UKJ-70、UKJ-95、UKJ-150、UKJ-240; UJ5-1.5、UJ5-2.5、UJ5-4、UJ5-6、UJ5-10、UJ5-16、UJ5-35、UJ5-1.5/2×2、UJ5-2.5/2×2、UJ5-4/2×2、UJ5-2.5/2-2、UJ5-2.5/1×2、UJ5-6S、UJ5-1.5/1×2、UJ5-1.5/2-2、UJ5-4/1×2、UJ5-4/2-2、UJ5-6/1×2、UJ5-10/1×2、UJ5-16/1×2、UJ5-6/2×2、UJ5-2.5WM、UJ5-1.5/2×2-U、UJ5-2.5/2×2-U、UJ5-4/2×2-U、UJ5-2.5W/2×2、UJ5-2.5W、UJ5-1.5/2×2-PV、UJ5-2.5/2×2-PV、UJ5-4/2×2-PV、UJ5-2.5/2-2/L-N、UJ5-6/2×2-U。

防爆标志: Ex eb IIC Gb

批 准:



上海仪器仪表自控系统检验测试所有限公司



中国国家强制性产品认证证书



证书编号: 2020322313000216

附 件

电气参数:

型号	图纸编号	额定电压 (V)	额定导线规格 (mm ²)	最小力矩 (N·m)
UKJ-1.5	5YB.574.081	250	0.2-1.5	0.1
UKJ-1.5MT	5YB.574.129	200	0.2-1.5	0.1
UKJ-1.5MT/1×2	5YB.574.131	200	0.2-1.5	0.1
UKJ-1.5MT/2-2	5YB.574.133	200	0.2-1.5	0.1
UKJ-1.5MT/2×2	5YB.574.130	200	0.2-1.5	0.1
UKJ-2.5	5YB.574.039	400	0.2-2.5	0.15
UKJ-2.5X	5YB.574.062	400	0.2-2.5	0.18
UKJ-2.5M	5YB.574.082	200	0.2-2.5	0.18
UKJ-2.5N	5YB.574.156	400	0.2-2.5	0.18
UKJ-2.5E	5YB.574.466	400	0.2-2.5	0.15
UKJ-2.5NEE	5YB.574.805	400	0.2-2.5	0.15
UKJ-2.5EE	5YB.574.753	400	0.2-2.5	0.15
UKJ-2.5XE	5YB.574.049	400	0.2-2.5	0.18
UKJ-2.5XEE	5YB.574.743	400	0.2-2.5	0.24
UKJ-2.5/1×2	5YB.574.136	160	0.2-2.5	0.15
UKJ-2.5/2×2	5YB.574.112	250	0.2-2.5	0.15
UKJ-2.5/2-2	5YB.574.715	200	0.25-1.5	0.27

批 准:



上海仪器仪表自控系统检验测试所有限公司



中国国家强制性产品认证证书



证书编号: 2020322313000216

附 件

型号	图纸编号	额定电压 (V)	额定导线规格 (mm ²)	最小力矩 (N·m)
UKJ-2.5/2-2L	5YB.574.752	200	0.2-2.5	0.18
UKJ-2.5M/2-2	5YB.574.134	200	0.2-2.5	0.24
UKJ-2.5M/2×2	5YB.574.135	200	0.2-2.5	0.21
UKJ-4	5YB.574.040	400	0.2-4	0.31
UKJ-4C	5YB.574.073	200	0.2-2.5	0.45
UKJ-4M	5YB.574.083	250	0.2-4	0.2
UKJ-10	5YB.574.042	400	0.5-10	0.31
UKJ-10/2×2	5YB.574.098	400	0.5-10	0.45
UKJ-10/4×4	5YB.574.783	400	0.5-10	0.2
UKJ-10EE	5YB.574.776	400	0.5-10	0.27
UKJ-4E	5YB.574.467	400	0.2-4	0.18
UKJ-4 EE	5YB.574.774	400	0.2-4	0.24
UKJ-4/1×2	5YB.574.137	200	0.2-4	0.21
UKJ-4/2×2	5YB.574.054	320	0.2-2.5	0.21
UKJ-4/2×2L	5YB.574.705	200	0.2-2.5	0.18
UKJ-4/2-2	5YB.574.055	250	0.2-4	0.21
UKJ-4/2-2L	5YB.574.072	250	0.2-4	0.21

批 准:



上海仪器仪表自控系统检验测试所有限公司



中国国家强制性产品认证证书



证书编号: 2020322313000216

附 件

型号	图纸编号	额定电压 (V)	额定导线规格 (mm ²)	最小力矩 (N·m)
UKJ-6	5YB.574.041	400	0.2-6	0.27
UKJ-6S	5YB.574.057	200	0.5-6	0.27
UKJ-6SEE	5YB.574.509	250	1.5-6	1.0
UKJ-6SB	5YB.574.121	400	0.5-6	0.27
UKJ-6SE	5YB.574.468	200	0.5-6	0.27
UKJ-6M	5YB.574.084	400	0.5-6	0.27
UKJ-6EE	5YB.574.775	320	0.2-6	0.27
UKJ-6/3×6	5YB.574.812	400	0.2-6	0.27
UKJ-6/5×6	5YB.574.813	400	0.2-6	0.27
UKJ-W2.5	5YB.574.172	400	0.5-2.5	0.15
UKJ-W2.5/2-2	5YB.574.184	320	0.5-2.5	0.15
UKJ-W2.5/2×2	5YB.574.189	320	0.5-2.5	0.15
UKJ-W4	5YB.574.173	400	1.5-4	0.18
UKJ-DK1.5	5YB.574.158	200	0.2-2.5	0.24
UKJ-DKD1.5	5YB.574.160	160	0.2-2.5	0.24
UKJ-DLK4/JD	5YB.574.362	400	0.2-4	0.24
UKJ-VIOK1.5-3D/JD	5YB.574.409	200	0.2-2.5	0.20

批 准:



上海仪器仪表自控系统检验测试所有限公司



中国国家强制性产品认证证书



证书编号: 2020322313000216

附 件

型号	图纸编号	额定电压 (V)	额定导线规格 (mm ²)	最小力矩 (N·m)
UKJ-VIOK1.5-2D	5YB.574.408	200	0.2-2.5	0.24
UKJ-DKD1.5-PV	5YB.574.405	200	0.2-2.5	0.15
UKJ-DOKD1.5-TG	5YB.574.392	200	0.2-2.5	0.15
UKJ-DOK1.5	5YB.574.364	200	0.2-2.5	0.20
UKJ-DOK1.5-2D	5YB.574.393	200	0.2-2.5	0.15
UKJ-DKD1.5-TG	5YB.574.363	200	0.2-2.5	0.24
UKJ-16	5YB.574.043	320	4-16	1.2
UKJ-16EE	5YB.574.815	500	4-16	0.36
UKJ-25/4×6	5YB.574.535	500	0.5-6	0.8
UKJ-35	5YB.574.044	500	0.75-35	1.2
UKJ-35N	5YB.574.218	500	0.75-35	1.2
UKJ-35EE	5YB.574.968	500	0.75-35	2.0
UKJ-50	5YB.574.051	500	25-50	2.0
UKJ-70	5YB.574.672	630	25-70	5.0
UKJ-95	5YB.574.052	630	35-95	11.0
UKJ-150	5YB.574.053	630	50-150	10.0
UKJ-240	5YB.574.155	630	70-240	12.0

批 准:

邵新华



上海仪器仪表自控系统检验测试所有限公司



中国国家强制性产品认证证书



证书编号: 2020322313000216

附 件

型号	图纸编号	额定电压 (V)	额定导线规格 (mm ²)	最小力矩 (N·m)
UJ5-1.5	5YB.574.165	400	0.14-1.5	/
UJ5-2.5	5YB.574.166	400	0.2-2.5	/
UJ5-4	5YB.574.167	400	0.2-4	/
UJ5-6	5YB.574.168	400	0.5-6	/
UJ5-10	5YB.574.169	400	1.5-10	/
UJ5-16	5YB.574.170	400	1.5-16	/
UJ5-35	5YB.574.171	500	2.5-35	/
UJ5-1.5/2×2	5YB.574.206	320	0.2-1.5	/
UJ5-2.5/2×2	5YB.574.207	400	0.2-2.5	/
UJ5-4/2×2	5YB.574.208	320	0.2-4	/
UJ5-2.5/2-2	5YB.574.214	320	0.2-2.5	/
UJ5-2.5/1×2	5YB.574.216	400	0.2-2.5	/
UJ5-6S	5YB.574.230	400	0.5-6	/
UJ5-1.5/1×2	5YB.574.338	400	0.2-1.5	/
UJ5-1.5/2-2	5YB.574.340	400	0.2-1.5	/
UJ5-4/1×2	5YB.574.342	400	0.2-4	/
UJ5-4/2-2	5YB.574.344	320	0.2-4	/

批 准:



上海仪器仪表自控系统检验测试所有限公司



中国国家强制性产品认证证书



证书编号: 2020322313000216

附 件

型号	图纸编号	额定电压 (V)	额定导线规格 (mm ²)	最小力矩 (N·m)
UJ5-6/1×2	5YB.574.353	400	0.5-6	/
UJ5-10/1×2	5YB.574.355	400	1.5-10	/
UJ5-16/1×2	5YB.574.357	400	1.5-16	/
UJ5-6/2×2	5YB.574.359	400	0.5-6	/
UJ5-2.5WM	5YB.574.473	500	0.2-2.5	/
UJ5-1.5/2×2-U	5YB.574.492	320	0.2-1.5	/
UJ5-2.5/2×2-U	5YB.574.493	400	0.2-2.5	/
UJ5-4/2×2-U	5YB.574.494	320	0.2-4	/
UJ5-2.5W/2×2	5YB.574.501	500	0.2-2.5	/
UJ5-2.5W	5YB.574.502	500	0.2-2.5	/
UJ5-1.5/2×2-PV	5YB.574.551	400	0.14-1.5	/
UJ5-2.5/2×2-PV	5YB.574.552	320	0.2-2.5	/
UJ5-4/2×2-PV	5YB.574.553	320	0.2-4	/
UJ5-2.5/2-2/L-N	5YB.576.048	320	0.2-2.5	/
UJ5-6/2×2-U	5YB.576.053	320	0.5-6	/

批 准:



上海仪器仪表自控系统检验测试所有限公司



中国国家强制性产品认证证书



SITIAs
Worldwide Access

证书编号: 2020322313000216

附 件

相关报告编号: 2020S17402-000560
2022S17402-010284

使用条件:

特殊使用条件“X”:

1. 该产品为 Ex 元件, 与其他电气设备或系统一起使用时需附加认证, 不能单独使用。
2. 该产品工作温度为: $-20^{\circ}\text{C} \sim +85^{\circ}\text{C}$ 。
3. 当不同规格的接线端子组合安装时, 电气间隙和爬电距离须满足 GB/T3836.3-2021 的要求。
4. UKJ 系列产品的最小力矩不得低于电气参数表中规定值。

批 准:



上海仪器仪表自控系统检验测试所有限公司